

**IOWA CITY COMMUNITY
SCHOOL DISTRICT
RADON NOTIFICATION
FOR BUILDING OCCUPANTS**

Project Name:	Shimek Radon Test Results		
Owner Project #:			
Completed By:	Dave McKenzie	Date:	1/18/2013

Ground-level preschool classrooms are required by Iowa Code 441-109 to be tested for Radon every two years. Short-term (48 hour) tests were performed in rooms 9 and 10 by a certified Radon measurement specialist over winter break. The result of 5.0 for room 9 was above the “action limit” of 4.0 picocuries/liter.

At the time of the test, one of the Shimek heating/ventilating units was not operating. After it was repaired, rooms 9 and 10 were retested. The result of the retest in room 9 was 4.1. We will initiate a long-term test (90+ days) as outlined in step 6 of “The 10 Step Radon Action Plan” provided by the Iowa Department of Public Health. For your information, results of the two tests in room 10 were 1.3 and 0.7.

Additional information about Radon is available on the web at <http://www.idph.state.ia.us/radon> and <http://www.epa.gov/radon>.

Certified Radon Measurement Specialist: Stephen R. Burns, license no. S00227

Iowa Credentialed Radon Mitigation Specialist:

Mitigation Supervisor on Site:

Phone Number:

Phasing of Work:

Days and Hours Mitigation Work Will Commence:

ICCSD Contact Person: Dave McKenzie 319-430-2792

Rooms Affected: Room 9

Cc: Tom Yates, ICEA
Andy Gahan, ICEA
Coy Marquardt, ISEA/ECUU
Terry Conner
Effie Redig
Phyllis Tucker

David Dude
Duane Van Hemert
Chace Ramey
Jeff Barnes
Michelle Webster