

**IOWA CITY COMMUNITY
SCHOOL DISTRICT
RADON NOTIFICATION
FOR BUILDING OCCUPANTS**

Project Name:	Coralville Central Radon Test Results		
Owner Project #:			
Completed By:	Dave McKenzie	Date:	1/18/2013

Ground-level preschool classrooms are required by Iowa Code 441-109 to be tested for Radon every two years. A short-term (48 hour) test was performed in room 207 by a certified Radon measurement specialist over winter break. The result of 6.3 for room 207 was above the “action limit” of 4.0 picocuries/liter. We will initiate a long-term test (90+ days), as outlined in step 6 of “The 10 Step Radon Action Plan” provided by the Iowa Department of Public Health.

Additional information about Radon is available on the web at <http://www.idph.state.ia.us/radon> and <http://www.epa.gov/radon> .

Certified Radon Measurement Specialist: Stephen R. Burns, license no. S00227

Iowa Credentialed Radon Mitigation Specialist:

Mitigation Supervisor on Site:

Phone Number:

Phasing of Work:

Days and Hours Mitigation Work Will Commence:

ICCSO Contact Person: Dave McKenzie 319-430-2792

Rooms Affected: Room 207

Cc: Tom Yates, ICEA
Andy Gahan, ICEA
Coy Marquardt, ISEA/ECUU
Barb Jenkins
Jerry Murphy
Phyllis Tucker

David Dude
Duane Van Hemert
Chace Ramey
Jeff Barnes
Michelle Webster