

**IOWA CITY COMMUNITY
SCHOOL DISTRICT
RADON NOTIFICATION
FOR BUILDING OCCUPANTS**

Project Name:	Borlaug Radon Test Results		
Owner Project #:			
Completed By:	Dave McKenzie	Date:	2/19/2013

Ground-level preschool classrooms are required by Iowa Code 441-109 to be tested for Radon every two years. Short-term (48 hour) tests were performed in rooms 1105 and 1106 by a certified Radon measurement specialist over winter break, and initial results of 7.9 and 8.9 picocuries/liter were above the “action limit” of 4.0 picocuries/liter. Energy Recovery Unit #3 was found to be malfunctioning at that time.

After ERU #3 was repaired, rooms 1105 and 1106 were retested on Feb. 16-18. Results were 2.1 and 2.5 respectively. No further action is required.

Additional information about Radon is available on the web at <http://www.idph.state.ia.us/radon> and <http://www.epa.gov/radon>.

Certified Radon Measurement Specialist: Stephen R. Burns, license no. S00227

Iowa Credentialed Radon Mitigation Specialist:

Mitigation Supervisor on Site:	Phone Number:	
--------------------------------	---------------	--

Phasing of Work:

Days and Hours Mitigation Work Will Commence:

ICCSA Contact Person: Dave McKenzie 319-430-2792

Rooms Affected: 1105, 1106

Cc: Tom Yates, ICEA
Andy Gahan, ICEA
Coy Marquardt, ISEA/ECUU
Celeste Shoppa
Marge Polman
Phyllis Tucker

David Dude
Duane Van Hemert
Chace Ramey
Jeff Barnes
Michelle Webster