

**IOWA CITY COMMUNITY
SCHOOL DISTRICT
RADON NOTIFICATION
FOR BUILDING OCCUPANTS**

Project Name:	Borlaug Radon Test Results		
Owner Project #:			
Completed By:	Dave McKenzie	Date:	1/16/2013

Ground-level preschool classrooms are required by Iowa Code 441-109 to be tested for Radon every two years. Short-term (48 hour) tests were performed in rooms 1105 and 1106 by a certified Radon measurement specialist over winter break. Results of 7.9 and 8.9 picocuries/liter for the rooms were both above the “action limit” of 4.0 picocuries/liter.

Borlaug classroom ventilation is currently being affected by the malfunction of Energy Recovery Unit #3, a component of the Heating, Ventilation, and Air Conditioning system. Repair parts have been ordered, repairs will be made in the next one to two weeks, and then we will repeat the short-term tests. A long-term test (90+ days) will be performed if appropriate, based on the results of the retest. This follows the protocol of “The 10 Step Radon Action Plan” provided by the Iowa Department of Public Health.

Additional information about Radon is available on the web at <http://www.idph.state.ia.us/radon> and <http://www.epa.gov/radon>.

Certified Radon Measurement Specialist: Stephen R. Burns, license no. S00227

Iowa Credentialed Radon Mitigation Specialist:

Mitigation Supervisor on Site:

Phone Number:

Phasing of Work:

Days and Hours Mitigation Work Will Commence:

ICCSA Contact Person: Dave McKenzie 319-430-2792

Rooms Affected: 1105, 1106

Cc: Tom Yates, ICEA
Andy Gahan, ICEA
Coy Marquardt, ISEA/ECUU
Celeste Shoppa
Marge Polman
Phyllis Tucker

David Dude
Duane Van Hemert
Chace Ramey
Jeff Barnes
Michelle Webster